SIEMENS

Data sheet

6ES7516-3FN01-0AB0



SIMATIC S7-1500F, CPU 1516F-3 PN/DP, CENTRAL PROCESSING UNIT WITH WORKING MEMORY 1,5 MB FOR PROGRAM AND 5 MB FOR DATA, 1. INTERFACE: PROFINET IRT WITH 2 PORT SWITCH, 2. INTERFACE: PROFINET RT, 3. INTERFACE: PROFIBUS, 10 NS BIT-PERFORMANCE, SIMATIC MEMORY CARD NECESSARY

Figure similar

General information		
Product type designation	CPU 1516F-3 PN/DP	
HW functional status	FS01	
Firmware version	V1.8	
Engineering with		
 STEP 7 TIA Portal configurable/integrated as of version 	V13 SP1 Update 4	
Display		
Screen diagonal (cm)	6.1 cm	
Control elements		
Number of keys	6	
Mode selector switch	1	
Supply voltage		
Type of supply voltage	24 V DC	
permissible range, lower limit (DC)	19.2 V	
permissible range, upper limit (DC)	28.8 V	

Poweree polarity protection	Yes
Reverse polarity protection	Tes
Mains buffering	5
 Mains/voltage failure stored energy time 	5 ms
Input current	
Current consumption (rated value)	0.85 A
Inrush current, max.	2.4 A; Rated value
l²t	0.02 A ² ·s
Power	
Power consumption from the backplane bus	6.7 W
(balanced)	
Infeed power to the backplane bus	12 W
Power loss	
Power loss, typ.	7 W
Memory	
SIMATIC memory card required	Yes
Work memory	
 integrated (for program) 	1.5 Mbyte
 integrated (for data) 	5 Mbyte
Load memory	
 Plug-in (SIMATIC Memory Card), max. 	32 Gbyte
Backup	
maintenance-free	Yes
CPU processing times	
for bit operations, typ.	10 ns
for word operations, typ.	12 ns
for fixed point arithmetic, typ.	16 ns
for floating point arithmetic, typ.	64 ns
CPU-blocks	
Number of elements (total)	6 000; Blocks (OB, FB, FC, DB) and UDTs
DB	
 Number range 	1 60 999; subdivided into: number range that can be used by the user: 1 59 999, and number range of DBs created via SFC 86: 60 000 60 999
• Size, max.	5 Mbyte; For non-optimized block accesses, the max. size of the DB is 64 KB
FB	
Number range	0 65 535
• Size, max.	512 kbyte
FC	
Number range	0 65 535
• Size, max.	512 kbyte

OB	
• Size, max.	512 kbyte
 Number of free cycle OBs 	100
 Number of time alarm OBs 	20
 Number of delay alarm OBs 	20
 Number of cyclic interrupt OBs 	20
 Number of process alarm OBs 	50
 Number of DPV1 alarm OBs 	3
 Number of isochronous mode OBs 	2
 Number of technology synchronous alarm OBs 	2
 Number of startup OBs 	100
 Number of asynchronous error OBs 	4
 Number of synchronous error OBs 	2
 Number of diagnostic alarm OBs 	1
Nesting depth	
• per priority class	24; Up to 8 possible for F-blocks
Counters, timers and their retentivity	
S7 counter	
Number	2 048
Retentivity	
— adjustable	Yes
IEC counter	
Number	Any (only limited by the main memory)
Retentivity	
— adjustable	Yes
S7 times	
Number	2 048
Retentivity	
— adjustable	Yes
IEC timer	
• Number	Any (only limited by the main memory)
Retentivity	
— adjustable	Yes
Data areas and their retentivity	
Flag	
• Number, max.	16 kbyte
Number of clock memories	8; 8 clock memory bits, grouped into one clock memory byte
Data blocks	
Retentivity adjustable	Yes
Retentivity preset	No
Local data	

• per priority class, max.	64 kbyte; max. 16 KB per block
Address area	
Number of IO modules	8 192; max. number of modules / submodules
I/O address area	
Inputs	32 kbyte; All inputs are in the process image
Outputs	32 kbyte; All outputs are in the process image
per integrated IO subsystem	
— Inputs (volume)	8 kbyte
— Outputs (volume)	8 kbyte
per CM/CP	
— Inputs (volume)	8 kbyte
— Outputs (volume)	8 kbyte
Subprocess images	
 Number of subprocess images, max. 	32
Hardware configuration Number of distributed IO systems	20
Number of DP masters	20
integrated	1
• Via CM	 8; A maximum of 8 CMs/CPs (PROFIBUS, PROFINET, Ethernet)
	can be inserted in total
Number of IO Controllers	
 integrated 	1
• Via CM	8; A maximum of 8 CMs/CPs (PROFIBUS, PROFINET, Ethernet) can be inserted in total
Rack	
 Modules per rack, max. 	32; CPU + 31 modules
 Number of lines, max. 	1
PtP CM	
 Number of PtP CMs 	the number of connectable PtP CMs is only limited by the number of available slots
Time of day	
Clock	
• Туре	Hardware clock
Backup time	6 wk; At 40 °C ambient temperature, typically
 Deviation per day, max. 	10 s; Typ.: 2 s
Operating hours counter	
Number	16
Clock synchronization	
 supported 	Yes
• to DP, master	Yes
• in AS, master	Yes

• in AS, slave	Yes
• on Ethernet via NTP	Yes
luto efe e e e	
Interfaces Number of PROFINET interfaces	2
Number of PROFIBUS interfaces	1
1. Interface	
Interface types	
Number of ports	2
 integrated switch 	Yes
• RJ 45 (Ethernet)	Yes; X1
Functionality	
PROFINET IO Controller	Yes
PROFINET IO Device	Yes
 SIMATIC communication 	Yes
 Open IE communication 	Yes
Web server	Yes
Media redundancy	Yes
2. Interface	
Interface types	
Number of ports	1
• integrated switch	No
• RJ 45 (Ethernet)	Yes; X2
Functionality	
PROFINET IO Controller	No
PROFINET IO Device	No
SIMATIC communication	Yes
Open IE communication	Yes
• Web server	Yes
3. Interface	
Interface types	
Number of ports	1
• RS 485	Yes
Functionality	
PROFIBUS DP master	Yes
PROFIBUS DP slave	No
SIMATIC communication	Yes
Interface types	
RJ 45 (Ethernet)	
• 100 Mbps	Yes
 Autonegotiation 	Yes
-	

Autocrossing	Yes
Industrial Ethernet status LED	Yes
RS 485	
 Transmission rate, max. 	12 Mbit/s
Detect	
Protocols Number of connections	
Number of connections, max.	256; via integrated interfaces of the CPU and connected CPs /
	CMs
 Number of connections reserved for 	10
ES/HMI/web	
 Number of connections via integrated 	128
interfaces	
 Number of S7 routing paths 	16
PROFINET IO Controller	
Services	
— PG/OP communication	Yes
— S7 routing	Yes
— Isochronous mode	Yes
— Open IE communication	Yes
— IRT	Yes
— MRP	Yes; As MRP redundancy manager and/or MRP client; max. number of devices in the ring: 50
— PROFlenergy	Yes
— Prioritized startup	Yes; Max. 32 PROFINET devices
 — Number of connectable IO Devices, max. 	256; In total, up to 768 distributed I/O devices can be connected via PROFIBUS or PROFINET
— Of which IO devices with IRT, max.	64
 — Number of connectable IO Devices for RT, 	256
max.	
— of which in line, max.	256
— Number of IO Devices that can be	8
simultaneously activated/deactivated, max.	
— Number of IO Devices per tool, max.	8
— Updating times	The minimum value of the update time also depends on communication share set for PROFINET IO, on the number of IO devices, and on the quantity of configured user data
Update time for IRT	
— for send cycle of 250 μs	250 μs to 4 ms; Note: In the case of IRT with isochronous mode, the minimum update time of 500 μs of the isochronous OB is decisive
— for send cycle of 500 μs	500 µs to 8 ms
— for send cycle of 1 ms	1 ms to 16 ms
— for send cycle of 2 ms	2 ms to 32 ms

— for send cycle of 4 ms	4 ms to 64 ms
— With IRT and parameterization of "odd"	Update time = set "odd" send clock (any multiple of 125 µs: 375
send cycles	μs, 625 μs 3 875 μs)
Update time for RT	
- for send cycle of 250 μs	250 µs to 128 ms
— for send cycle of 500 μ s	500 µs to 256 ms
— for send cycle of 1 ms	1 ms to 512 ms
— for send cycle of 2 ms	2 ms to 512 ms
— for send cycle of 4 ms	4 ms to 512 ms
PROFINET IO Device	
Services	
— PG/OP communication	Yes
— S7 routing	Yes
— Isochronous mode	No
— Open IE communication	Yes
— IRT	Yes
— MRP	Yes
— PROFlenergy	Yes
— Shared device	Yes
 — Number of IO Controllers with shared device, max. 	4
SIMATIC communication	
 S7 communication, as server 	Yes
 S7 communication, as client 	Yes
● User data per job, max.	See online help (S7 communication, user data size)
Open IE communication	
• TCP/IP	Yes
— Data length, max.	64 kbyte
 — several passive connections per port, supported 	Yes
• ISO-on-TCP (RFC1006)	Yes
— Data length, max.	64 kbyte
• UDP	Yes
— Data length, max.	1 472 byte
• DHCP	No
• SNMP	Yes
• DCP	Yes
• LLDP	Yes
Web server	
• HTTP	Yes; Standard and user-defined pages
• HTTPS	Yes; Standard and user-defined pages
PROFIBUS DP master	

Number of connections, max. 48; for the integrated PROFIBUS DP interface PG/OP communication PG/OP communication Yes S7 routing Yes Data record routing Yes Data record routing Yes Equidistance Yes Number of DP slaves Yes Ves Activation/deactivation of DP slaves Yes Ves Activation/deactivation of DP slaves Yes Ves Activation/deactivation of DP slaves Yes Ves Ves Activation/deactivation of DP slaves Yes Ves Ves
PG/OP communicationYes- S7 routingYes- Data record routingYes- Data record routingYes- Isochronous modeYes- EquidistanceYes- EquidistanceYes- Activation/deactivation of DP slavesYes- Activation/deactivation of DP slavesYes- Activation/deactivation of DP slavesYes- Activation/deactivation of DP slavesYesFurther protocolsYes; MODBUS TCPMedia redundancy200 ms• Number of stations in the ring, max.50sochronous operation (application synchronized up to terminal)Yes; With minimum OB 6x cycle of 375 µsSolar configurable alarms, max.10 000Number of login stations for message functions, max.32Block related messagesYesNumber of reserved alarms for system cligonostics200Number of reserved alarms for system cligonostics200Number of reserved alarms for Motion Control technology objects200Fest commissioning functions200Fest commissioning functions200Source Street Street alarms for Motion Control technology objects160
- Data record routingYes- Isochronous modeYes- EquidistanceYes- Number of DP slaves125; In total, up to 768 distributed I/O devices can be connected via PROFIBUS or PROFINET- Activation/deactivation of DP slavesYesFurther protocolsYes; MODBUS or PROFINET• MODBUSYes; MODBUS TCPMedia redundancy200 ms• Switchover time on line break, typ. • Number of stations in the ring, max.200 ms• Sochronous operation (application synchronized up to terminal)Yes; With minimum OB 6x cycle of 375 µsEquidistanceYesSochronous operation (application synchronized up to terminal)Yes; With minimum OB 6x cycle of 375 µsEquidistanceYesNumber of login stations for message functions, max.32Block related messagesYesNumber of reserved user alarms in alarm pool600• Number of reserved alarms for system diagnostics200• Number of reserved alarms for Motion Control technology objects160Fest commissioning functions160
- Isochronous modeYes- EquidistanceYes- Number of DP slaves125; In total, up to 768 distributed I/O devices can be connected via PROFIBUS or PROFINET- Activation/deactivation of DP slavesYesFurther protocolsYes; MODBUS TCP• MODBUSVes; MODBUS TCPMedia redundancy200 ms• Switchover time on line break, typ. to terminal)200 ms• Sochronous operation (application synchronized up to terminal)Yes; With minimum OB 6x cycle of 375 µs• Kumber of login stations for message functions, max.32Slock related messagesYesNumber of onfigurable alarms, max.10 000Number of reserved user alarms in alarm pool600• Number of reserved alarms for system diagnostics600• Number of reserved alarms for System diagnostics600• Number of reserved alarms for Motion Control technology objects160
EquidistanceYes- EquidistanceYes- Number of DP slaves125; In total, up to 788 distributed I/O devices can be connected via PROFIBUS or PROFINET- Activation/deactivation of DP slavesYesFurther protocolsYes; MODBUS TCPMoDBUSYes; MODBUS TCPMedia redundancy200 ms• Number of stations in the ring, max.50sochronous modeSochronous operation (application synchronized up to terminal)EquidistanceYesNumber of login stations for message functions, max.32Block related messagesYesNumber of onfigurable alarms, max.10 000Number of reserved user alarms600• Number of reserved alarms for system diagnostics600• Number of reserved alarms for Motion Control tetchnology objects160Fest commissioning functions160
via PROFIBUS or PROFINET Activation/deactivation of DP slavesYesFurther protocolsYes; MODBUS TCPModia redundancy200 ms- Switchover time on line break, typ.200 ms- Number of stations in the ring, max.50sochronous operation (application synchronized up to terminal)Yes; With minimum OB 6x cycle of 375 µsEquidistanceYesNumber of login stations for message functions, max.32Block related messagesYesNumber of simultaneously active alarms in alarm pool10 000Number of reserved user alarms for system diagnostics200Number of reserved alarms for Motion Control technology objects160
Further protocols Formation of energy of the second of
• MODBUSYes; MODBUS TCPMedia redundancy200 ms• Switchover time on line break, typ.200 ms• Number of stations in the ring, max.50sochronous modeIsochronous operation (application synchronized up to terminal)EquidistanceYes; With minimum OB 6x cycle of 375 µsOffer Stations for message functions, max.S7 message functions32Block related messagesYesNumber of login stations for message functions, max.32Block related messagesYesNumber of simultaneously active alarms in alarm pool600• Number of reserved user alarms600• Number of reserved alarms for Motion Control technology objects200Fest commissioning functions160
Media redundancy200 ms• Switchover time on line break, typ.200 ms• Number of stations in the ring, max.50sochronous modeYes; With minimum OB 6x cycle of 375 µsIsochronous operation (application synchronized up to terminal)Yes; With minimum OB 6x cycle of 375 µsEquidistanceYes57 message functionsYesNumber of login stations for message functions, max.32Block related messagesYesNumber of configurable alarms, max.10 000Number of reserved user alarms in alarm pool600• Number of reserved user alarms for system diagnostics • Number of reserved alarms for Motion Control technology objects600Fest commissioning functions160
• Switchover time on line break, typ.200 ms• Number of stations in the ring, max.50sochronous modeIsochronous operation (application synchronized up to terminal)Yes; With minimum OB 6x cycle of 375 µsEquidistanceYesS7 message functionsYesNumber of login stations for message functions, max.32Block related messagesYesNumber of configurable alarms, max.10 000Number of reserved user alarms in alarm pool600• Number of reserved alarms for system diagnostics200• Number of reserved alarms for Motion Control technology objects160Fest commissioning functions160
e Number of stations in the ring, max.50sochronous modeYes; With minimum OB 6x cycle of 375 µsIsochronous operation (application synchronized up to terminal)Yes; With minimum OB 6x cycle of 375 µsEquidistanceYesS7 message functions32Block related messagesYesNumber of login stations for message functions, max.32Block related messagesYesNumber of configurable alarms, max.10 000Number of simultaneously active alarms in alarm pool600• Number of reserved user alarms for system diagnostics600• Number of reserved alarms for Motion Control technology objects160
sochronous mode Isochronous operation (application synchronized up to terminal) Yes; With minimum OB 6x cycle of 375 µs Equidistance Yes S7 message functions 32 Block related messages Yes Number of login stations for message functions, max. 32 Block related messages Yes Number of configurable alarms, max. 10 000 Number of reserved user alarms in alarm pool 600 • Number of reserved user alarms for system diagnostics 200 • Number of reserved alarms for Motion Control technology objects 160
Isochronous operation (application synchronized up to terminal)Yes; With minimum OB 6x cycle of 375 µsEquidistanceYesS7 message functionsYesNumber of login stations for message functions, max.32Block related messagesYesNumber of configurable alarms, max.10 000Number of reserved user alarms600• Number of reserved user alarms for system diagnostics200• Number of reserved alarms for Motion Control technology objects160
Isochronous operation (application synchronized up to terminal)Yes; With minimum OB 6x cycle of 375 µsEquidistanceYesS7 message functionsYesNumber of login stations for message functions, max.32Block related messagesYesNumber of configurable alarms, max.10 000Number of reserved user alarms600• Number of reserved user alarms for system diagnostics200• Number of reserved alarms for Motion Control technology objects160
to terminal)YesEquidistanceYesS7 message functions32Number of login stations for message functions, max.32Block related messagesYesNumber of configurable alarms, max.10 000Number of simultaneously active alarms in alarm pool600• Number of reserved user alarms600• Number of reserved alarms for system diagnostics • Number of reserved alarms for Motion Control technology objects160Fest commissioning functionsFest commissioning functions
S7 message functions 32 Number of login stations for message functions, max. 32 Block related messages Yes Number of configurable alarms, max. 10 000 Number of simultaneously active alarms in alarm pool 600 • Number of reserved user alarms for system diagnostics 200 • Number of reserved alarms for Motion Control technology objects 160
Number of login stations for message functions, max.32Block related messagesYesNumber of configurable alarms, max.10 000Number of simultaneously active alarms in alarm pool600• Number of reserved user alarms600• Number of reserved alarms for system diagnostics200• Number of reserved alarms for Motion Control technology objects160
Block related messages Yes Number of configurable alarms, max. 10 000 Number of simultaneously active alarms in alarm pool 600 • Number of reserved user alarms 600 • Number of reserved alarms for system diagnostics 200 • Number of reserved alarms for Motion Control technology objects 160
Number of configurable alarms, max.10 000Number of simultaneously active alarms in alarm pool600• Number of reserved user alarms600• Number of reserved alarms for system diagnostics • Number of reserved alarms for Motion Control technology objects160Test commissioning functions
Number of simultaneously active alarms in alarm 600 • Number of reserved user alarms 600 • Number of reserved alarms for system 200 diagnostics 160 • Number of reserved alarms for Motion Control technology objects 160
pool600• Number of reserved user alarms600• Number of reserved alarms for system diagnostics200• Number of reserved alarms for Motion Control technology objects160Test commissioning functions
• Number of reserved user alarms600• Number of reserved alarms for system diagnostics200• Number of reserved alarms for Motion Control technology objects160Test commissioning functions
 Number of reserved alarms for system diagnostics Number of reserved alarms for Motion Control technology objects 160 Test commissioning functions
diagnostics Number of reserved alarms for Motion Control technology objects 160 Test commissioning functions
Test commissioning functions
Joint commission (Team Engineering) Yes; Parallel online access possible for up to 8 engineering systems
Status block Yes; Up to 8 simultaneously (in total across all ES clients)
Single step No
Status/control
Status/control variable Yes
Variables Inputs, outputs, memory bits, DB, times, counters
Number of variables, max.
— of which status variables, max. 200; per job
— of which control variables, max. 200; per job
Forcing

 Forcing, variables 	Peripheral inputs/outputs
 Number of variables, max. 	200
Diagnostic buffer	200
• present	Yes
·	3 200
Number of entries, max.	500
— of which powerfail-proof Traces	500
Number of configurable Traces	4; Up to 512 KB of data per trace are possible
Interrupts/diagnostics/status information	
Diagnostics indication LED	
RUN/STOP LED	Yes
• ERROR LED	Yes
MAINT LED	Yes
 Connection display LINK TX/RX 	Yes
Supported technology objects	
Motion Control	Yes
 Speed-controlled axis 	
 Number of speed-controlled axes, max. 	30; Requirement: There must be no other motion technology objects created
 Positioning axis 	
— Number of positioning axes, max.	30; Requirement: There must be no other motion technology objects created
 Synchronized axes (relative gear synchronization) 	
— Number of axes, max.	15; Requirement: There must be no other motion technology objects created
• External encoders	
— Number of external encoders, max.	30; Requirement: There must be no other motion technology objects created
Controller	
PID_Compact	Yes; Universal PID controller with integrated optimization
PID_3Step	Yes; PID controller with integrated optimization for valves
• PID-Temp	Yes; PID controller with integrated optimization for temperature
Counting and measuring	
High-speed counter	Yes
Standards, approvals, certificates	
Highest safety class achievable in safety mode	
Probability of failure (for service life of 20 years and repair time of 100 hours)	
 Low demand mode: PFDavg in accordance with SIL3 	< 2.00E-05
 High demand/continuous mode: PFH in accordance with SIL3 	< 1.00E-09

Ambient conditions	
Ambient temperature during operation	
 horizontal installation, min. 	0°0
 horizontal installation, max. 	60 °C; Display: 50 °C, at an operating temperature of typically 50 °C, the display is switched off
 vertical installation, min. 	0 °C
• vertical installation, max.	40 °C; Display: 40 °C, at an operating temperature of typically 40 °C, the display is switched off

Programming	
Programming language	
— LAD	Yes; incl. failsafe
— FBD	Yes; incl. failsafe
— STL	Yes
— SCL	Yes
— GRAPH	Yes
Know-how protection	
 User program protection 	Yes
Copy protection	Yes
 Block protection 	Yes
Access protection	
 Password for display 	Yes
 Protection level: Write protection 	Yes
 Protection level: Read/write protection 	Yes
 Protection level: Complete protection 	Yes
Cycle time monitoring	
lower limit	adjustable minimum cycle time
• upper limit	adjustable maximum cycle time
Dimensions	
Width	70 mm
Height	147 mm
Depth	129 mm
Weights	
Weight, approx.	845 g
last modified:	12/06/2016

Configuration